



ALUMINUM FLANGE BOLT HOLE PATTERN

MODEL	A		VOLUME		DOME VOLUME		WEIGHT					
	mm	inch	liters	U.S. gal	liters	U.S. gal	kg	lbs				
36x72	2213	87.13	15	0.59	970	256.3	34.28	125.8	33.21	4.44	132.6	292.1

Direction A
1:3

NOTES:

- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- OPERATING SPECIFICATIONS:
 - MAXIMUM WORKING PRESSURE - 150 PSI (10.5BAR)
 - TEMPERATURE RANGE - 34-150° F (-65°C)
 - MAXIMUM VACUUM - 5"Hg (127mm Hg)
- VISUAL LINER INSPECTION
 - NO MORE THAN 20 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 5×5mm.
 - NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- SURFACE FINISH.
- DIMENSIONS IN PARENTHESES ARE REFERENCE ONLY.
- DIMENSIONS IN SQUARE PARENTHESES ARE INCH UNIT.
- TANK TO BE BONDED TO BASE.
- USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OR LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS WHEN PLACED ON THE TOP OF THE FLANGE.
- AFTER THE TANK IS LEVELED, IT IS RECOMMENDED THAT THE TANK BE BOLTED TO THE FLOOR IN SIX POSITIONS PER THE TRIPOD BASE BOLT HOLE PATTERN WITH 3/8" ANCHORS.

1		ADDED DIMENSION A		2011/08/29	
0		FIRST VERSION		2007/06/04	
REPRESENTATIVE PLASTIC SHRINKAGE (IF NECESSARY):				SIGNATURE	
SIGNATURE				DATE	
DESIGN		NAME		DATE	
INSPECTION					
APPROVAL					
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.					
DO NOT RESIZE THE DIMENSIONS.		UNIT: MM		TOTAL PAGE: 1	
SCALE		MATERIAL		MODEL	
1 : 10				DESCRIPTION	
QUANTITY		SMOOTHNESS		36" (PIPE BASE)	
PROJECTION		COMPUTER CODE		DRAWING NO.	
FIRST ANGLE				113367-00	
				VERSION NO.	
				1	

WAVE CYBER (SHANGHAI) CO., LTD.

36" (PIPE BASE)